






Wiring diagram of the Power Block - Receiver for wireless foot controllers used for
MODEL PRO 500 (DC 310), MODEL PRO 700 (DC 350), DC 240, DC 290, DL 210, DL 270, DL 290, DL 320, DL 330, DL 340, DL 380,
MODEL PRO 600 (DA 270), DA 280, MODEL PRO 800 (DA 370), DA 380
 (7.7.2022)



PUSH and hold TL1 and restart Dental Unit ->
 Wait for 5 min -> TURN OFF Dental Unit -> Turn ON Dental Unit

LEDs:
 LD1 (OG) ~ Communication
 LD2 (GN) ~ Not used
 LD3 (GN) ~ Not used
 LD4 (GN) ~ +5V
 LD5 (GN) ~ Successfully paired
 LD6 (GN) ~ System running indication
 LD7 (GN) ~ Charger cable in

TL1 ~ Pairing Button (only for economy)
 SW1 ~ Not used (OFF)

X1 ~ CAN output for Foot controller
 X2 ~ Pairing Button (only for economy)
 X3 ~ Programming connector
 X4 ~ CAN Input from power block module
 X5 ~ Foot Controller Detect (functionality test - connect pins with jumper the LED will light up)

